

*phone* (509) 354-7174 *fax* (509) 354-7183 www.spokaneschools.org



September 30, 2016

## RE: Bid No. 10-1617 ADDENDUM NO. 1

## 1. SCOPE OF WORK: Additional Information

- A. All current SPS Ballasts are T-8 Electronic Ballasts
- B. LED Lamps
  - 1. Must be DLC Qualified
  - 2. LED Lamps required are a direct replacement of 32 Watt/48T8 Fluorescent for use with Electronic Ballast
  - 3. 12.5 15 Watt Maximum
  - 4. Suitable to replace T8 fluorescent lamps
  - 5. A life of 50,000 hours
  - 6. Operate on instant-start and programmed-start ballasts as well as dimmable programmed-start ballasts.
  - 7. Must be qualified for the Avista Rebate Program Qualified product list can be found at <u>www.designlights.org</u>

End of Addendum No. 1

Thank You

Barb Carson

Barb Carson Purchasing Services